

- DIAGRAM NOT TO SCALE
- CONTACT NOLIN RECC LINE DESIGN DEPARTMENT BEFORE STARTING ANY WORK
- CALL 811 BEFORE DIGGING



A Touchstone Energy® Cooperative

MAIN OFFICE: 270-765-6153

DRAWN BY:
LANDER RYAN

APPROVED BY:
GREG LEE

**PERMANENT OVERHEAD
SERVICE WITH
UNDERGROUND FEEDER**


LAST REVISION

5/30/2018

NOTES

1. Overhead service locations must be approved by Nolin’s Line Design Department prior to service installation.
2. Overhead service will be allowed only under special circumstances.
3. Meter base with by-pass lever is furnished by consumer. Do not use a small meter base.
4. Consumer conduit and wire must meet state electrical code requirements.
5. Square pole not acceptable. Pole must be round with minimum 5” top.
6. Pole must be minimum 25’- with 20’ above ground and 5’ in ground.
7. All electric connections, equipment, and equipment grounds shall comply with the National Electrical Code.
8. The member shall furnish and maintain for the life of the electrical service all conduits, conduit straps, grounds, disconnects, meter base, and all conductors beyond Nolin’s point of delivery.
9. Nolin shall furnish and maintain the meter and service drop.
10. Energizing of the member’s service is contingent upon an approved State or City electrical inspection.



A Touchstone Energy® Cooperative 
MAIN OFFICE: 270-765-6153

DRAWN BY:
LANDER RYAN

APPROVED BY:
GREG LEE

**PERMANENT OVERHEAD
SERVICE WITH
UNDERGROUND FEEDER**

LAST REVISION

5/30/2018